


- DRAWING NOTES:**
- DUCTING SHALL COMPLY WITH BS EN 50086-1-2-3-4 LATEST EDITION & SHALL BE SINGLE WALL, COLOURED RED & MANUFACTURED FROM HIGH DENSITY POLYETHYLENE. THE NOMINAL EXTERNAL DIAMETER OF THE DUCT SHALL BE 107mm WITH A NOMINAL WALL THICKNESS OF 5mm. EACH LENGTH OF DUCT SHALL BE STAMPED WITH THE WORDS "PUBLIC LIGHTING" OR ALTERNATIVELY "STREET LIGHTING" IN 18mm BLACK LETTERING AT 2 DEGREES, AT ONE END AT INTERVALS. DUCT SHALL BE LAID WITH THIS LEGEND FACING UPWARDS. DUCT SHALL BE LAID IN A STRAIGHT LINE CLOSE TO THE LINE OF THE COLUMN LOCATIONS & SHALL CONTAIN A CONTINUOUS DRAW WIRE OF 8KN STRENGTH.
 - A MINIMUM DEPTH OF 450mm COVER IS REQUIRED IN URBAN PATHWAYS & A MINIMUM OF 600mm COVER IS REQUIRED FOR GRASS MARGINS, PESTERIAN WAYS, LANWAYS & GATEWAY ENTRANCES & A MINIMUM DEPTH OF 750mm IS REQUIRED AT ROAD CROSSINGS OR IN CARRIAGEWAYS.
 - ALL EQUIPMENT TO BE SUITABLY IP RATED FOR THE ENVIRONMENT THEY ARE BEING INSTALLED.
 - FOR SCHEDULES OF EQUIPMENT SEE SPECIFICATION.
 - THE COMPLETE INSTALLATION TO BE CO-ORDINATED WITH ALL OTHER SERVICES.

- LEGEND OF SYMBOLS:**
- EX-ESB (M/V/LV) DUCT
 - EX-ESB (LV) DUCT
 - EX-ER DUCT
 - ER MANHOLE/DRAWPIT
 - ESB
 - 4No. 125mm ϕ ESB DUCT
 - 2No. 100mm ϕ ESB DUCT
 - 2No. 100mm ϕ COMMS DUCT
 - ESB MINI PILLAR
 - ESB MANHOLE/DRAWPIT
 - ELECTRIC VEHICLE CHARGE (EVC)

- FOR SETTING OUT REFER TO ARCHITECT'S DRAWINGS.
- THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER ARCHITECTURAL AND ENGINEERING DRAWINGS AND ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS.
- DO NOT SCALE THIS DRAWING. USE FIGURED DIMENSIONS ONLY.
- NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OF ANY NATURE WITHOUT THE WRITTEN PERMISSION OF O'CONNOR SUTTON CROWIN AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR USE ON THE PROJECT FOR WHICH THE DOCUMENT WAS ORIGINALLY ISSUED.

Rev No.	Date	Revision Note	Drn by	Chkd by
PO1	24.10.22	SUITABLE FOR PLANNING	I.F.	A.M.

Rev No.	Date	Revision Note	Drn by	Chkd by



Head Office:
9 Prussia Street,
Dublin 7,
D07 KT57

TEL +353 (0)1 8682000
e: contactus@ocsc.ie
w: www.ocsc.ie

Dublin | London | Belfast | Galway | Cork | Birmingham

Client: CORK COUNTY COUNCIL
Project: CROSSHAVEN LOWER ROAD, Co.CORK
Title: ELECTRICAL SITE SERVICES LAYOUT SITE PLAN

Code [Originator] [Zone] [Level] [Type] [Role] [Number] [Status] [Revision]
C1003 OCSC XX XX DR E 0001 S4 | PO1
Date: 05.04.22 Scale: 1:250 @ A0 Drn by: I.F. Chkd by: A.M. Aprvd by: M.F.